



AGUSAN DEL SUR STATE COLLEGE OF AGRICULTURE AND TECHNOLOGY
P-1, San Teodoro, Bunawan, Agusan del Sur 8506
website: www.asscat.edu.ph
e-mail address: op@asscat.edu.ph
mobile no: +639483679266

Supplemental Bid Bulletin No. 01

Project: Supply, Delivery and Installation of Three (3) Units 100 KVA Distribution Transformer for Engineering/BIT Laboratory

This Supplemental Bid Bulletin is issued to all prospective bidders to clarify, modify and/or amend items in the Bidding Documents as discussed and agreed during the Pre-bid Conference held on January 17, 2023 at 10:00 o'clock in the morning at the Board Room, ASSCAT, San Teodoro, Bunawan, Agusan del Sur.

A. Additional Technical Specifications:

It includes the supply, delivery and installation of the following:

1. One (1) Unit 35 Feet Steel Post
2. Six (6) Units Cut-out and Arrester
3. Transformer Grounding
4. 300 Meters 250mm² THW Copper Wire

B. Technical Components consists of Legal and Technical Documents:

1. Any proof of Renewal such as Official Receipt, Application for Renewal and Certificate of Renewal must be attached as part of the Legal Documents for those bidders who have not yet renewed their Mayor's Permit.
2. PCAB License is not required in the Technical Documents.

C. Clarification on the Approved Budget for the Contract (ABC) as stated in the Bidding Documents (*Funding Information Page 11*)

Interested bidders are informed that the original Approved Budget for the Contract (ABC) is Two Million Five Hundred Forty Thousand Four Hundred Ninety-Seven Pesos and 50/100 (Php 2,540,497.50).

D. Bidders are informed that the Three (3) Units 20:5 Current Transformer, Three (3) Units 70:1 Potential Transformer, Electrical Permit, Energization Cost and Transformer Platform will be shouldered by the Procuring Entity.

E. Bidders are reminded that the winning bidder of the said project must apply ACCREDITATION to the Agusan del Sur Electric Cooperative, Inc. (ASELCO).

For guidance and information of all concerned.


RUTH S. DESAMPARO
BAC Chairperson